

	School District:	Schenectady City School								
	School Name:	Mont Pleasant								
Sample #	Location	Source	Sample Da	Results (ppb)	Initial Status*	Remediation	Remediation	Resample Date	Resample Resu	Status*
MPMS-001	3rd Floor Library Office	sink		6.3	Passed					
MPMS-002	3rd Floor Library Bathroom Room 301J	sink		5.3	Passed					
MPMS-003	3rd Floor Hallway outside Room 307	water fountain		<0.10	Passed					
MPMS-004	2nd Floor Room 267	sink #1		38.4	Failed			8/29/2018	ND	
MPMS-005	2nd Floor Room 267	sink #2		46.9	Failed			8/29/2018	ND	
MPMS-006	2nd Floor Room 265	sink #1		23.0	Failed			8/29/2018	ND	
MPMS-007	2nd Floor Room 265	sink #2		11.9	Passed					
MPMS-008	2nd Floor Hallway across from Room 207	water fountain		<0.10	Passed					
MPMS-009	2nd Floor Room 206	sink #1		12.4	Passed					
MPMS-010	2nd Floor Room 206	sink #2		9.4	Passed					
MPMS-011	2nd Floor Room 246	sink #1		18.2	Failed			8/29/2018	ND	
MPMS-012	2nd Floor Room 246	sink #2		15.8	Failed			8/29/2018	ND	
MPMS-013	2nd Floor Hallway outside Room 245	water fountain		<0.10	Passed					
MPMS-014	2nd Floor Hallway across from Girls Gym	water fountain		1.5	Passed					
MPMS-015	2nd Floor Girls Gym Office	sink		166	Failed			8/29/2018	ND	
MPMS-016	2nd Floor Room 222	sink #1		101	Failed			8/29/2018	ND	
MPMS-017	2nd Floor Room 222	sink #2		337	Failed			8/29/2018	ND	
MPMS-018	2nd Floor Room 222	sink #3		73.4	Failed			8/29/2018	ND	
MPMS-019	2nd Floor Room 222	sink #4		63.5	Failed			8/29/2018	ND	
MPMS-020	2nd Floor Room 222	sink #5		69.8	Failed			8/29/2018	ND	
MPMS-021	2nd Floor Room 220	sink #1		34.3	Failed			8/29/2018	ND	
MPMS-022	2nd Floor Room 220	sink #2		64.6	Failed			8/29/2018	ND	
MPMS-023	2nd Floor Room 220	sink #3		65.9	Failed			8/29/2018	ND	
MPMS-024	2nd Floor Room 220	sink #4		16.7	Failed			8/29/2018	ND	
MPMS-025	2nd Floor Room 220	sink #5		14.8	Passed					
MPMS-026	2nd Floor Room 230	sink #1		49.6	Failed			8/29/2018	ND	
MPMS-027	2nd Floor Room 230	sink #2		93.5	Failed			8/29/2018	ND	
MPMS-028	2nd Floor Room 230	sink #3		13.8	Passed					
MPMS-029	2nd Floor Room 230	sink #4		37.8	Failed			8/29/2018	ND	
MPMS-030	2nd Floor Hallway across from Cafeteria	water fountain		1.0	Passed					
MPMS-031	2nd Floor Cafeteria	water fountain		NO SAMPLE	Passed					
MPMS-032	2nd Floor Cafeteria Kitchen	sink #1		9.4	Passed					

MPMS-033	2nd Floor Cafeteria Kitchen	sink #2		22.8	Failed			8/29/2018	ND	
MPMS-034	2nd Floor Cafeteria Kitchen	sink #3		3.8	Passed					
MPMS-035	1st Floor Hallway across from Room 129	water fountain		2.0	Passed					
MPMS-036	1st Floor Room 129	sink		NO SAMPLE	Passed					
MPMS-037	1st Floor Room 123	sink #1		NO SAMPLE	Passed					
MPMS-038	1st Floor Room 123	sink #2		NO SAMPLE	Passed					
MPMS-039	1st Floor Room 123	sink #3		NO SAMPLE	Passed					
MPMS-040	1st Floor Room 123	sink #4		NO SAMPLE	Passed					
MPMS-041	1st Floor Room 123	sink #5		NO SAMPLE	Passed					
MPMS-042	1st Floor Room 122	sink		NO SAMPLE	Passed					
MPMS-043	1st Floor Room 128	sink #1		NO SAMPLE	Passed					
MPMS-044	1st Floor Room 128	sink #2		10.9	Passed					
MPMS-045	1st Floor Room 128	sink #3		20.6	Failed			8/29/2018	ND	
MPMS-046	1st Floor Room 128	sink #4		25.1	Failed			8/29/2018	ND	
MPMS-047	1st Floor Room 128	sink #5		26.5	Failed			8/29/2018	ND	
MPMS-048	1st Floor Custodial Office	sink		1.7	Passed					
MPMS-049	1st Floor Hallway next to Room 117	water fountain		2.4	Passed					
MPMS-050	1st Floor Hallway next to Room 129L	water fountain		1.1	Passed					
MPMS-052	1st Floor Main Gym next to Boys Locker Room	water fountain		0.18	Passed					
MPMS-053	1st Floor Room 116	sink #1		7.4	Passed					
MPMS-054	1st Floor Room 116	sink #2		11.0	Passed					
MPMS-055	1st Floor Room 114	sink #1		5.8	Passed					
MPMS-056	1st Floor Room 114	sink #2		3.7	Passed					
MPMS-057	1st Floor Room 165	sink #1		11.7	Passed					
MPMS-058	1st Floor Room 165	sink #2		20.1	Failed			8/29/2018	ND	
MPMS-059	1st Floor Room 167	sink #1		17.9	Failed			8/29/2018	ND	
MPMS-060	1st Floor Room 167	sink #2		13.0	Passed					
MPMS-061	1st Floor Hallway next to Room 106	water fountain		<0.10	Passed					
MPMS-062	1st Floor Hometown Health Center Suite 109	sink #1		3.5	Passed					
MPMS-063	1st Floor Hometown Health Center Suite 109	sink #2		5.5	Passed					
MPMS-064	1st Floor Hometown Health Center Suite 109	sink #3		5.0	Passed					
MPMS-065	1st Floor Hometown Health Center Suite 109	sink #4		3.1	Passed					
MPMS-066	1st Floor Hometown Health Center Suite 109	sink #5		3.5	Passed					
MPMS-067	1st Floor Nurses Office	sink #1		13.8	Passed					
MPMS-068	1st Floor Nurses Office	sink #2		3.5	Passed					

MPMS-069	1st Floor Nurses Office	sink #3		1.2	Passed					
MPMS-070	1st Floor Nurses Office Bathroom	sink		1.1	Passed					
MPMS-071	1st Floor Hallway outside Main Office	water fountain		0.25	Passed					
MPMS-072	1st Floor Room 146	sink		14.7	Passed					
MPMS-073	1st Floor Room 180	sink		9.4	Passed					
MPMS-074	1st Floor Room 183	sink		<0.10	Passed					
MPMS-075	1st Floor Hallway outside Office of C & Inst.	water fountain		1.6	Passed					
MPMS-076	1st Floor O & M shop	sink with water fountain		0.68	Passed					

