

	School District:	Schenectady City School							
	School Name:	Schenectady High							
Sample #	Location	Source	Sample	Results (ppb)	Initial Status*	Remediation	Remediation	Resample Date	Resample Results (ppb)
SHS-001	Hallway outside Main Gym #1	water fountain		3.2	Passed				
SHS-002	Hallway outside Main Gym #2	water fountain		3.6	Passed				
SHS-003	Boys Locker Room Office	sink #1		1.4	Passed				
SHS-004	Boys Locker Room Office	sink #2		20.8	Failed			10/11/2018	
SHS-005	Weight Room	water fountain		30.1	Failed			10/11/2018	1
SHS-006	Main Gym	water fountain #1		48.8	Failed			10/11/2018	1.1
SHS-007	Main Gym	water fountain #2		1.2	Passed				
SHS-008	Main Gym	water fountain #3		12.2	Passed				
SHS-009	Training Room	sink		8.9	Passed				
SHS-010	Training Room	Ice Machine		0.27	Passed				
SHS-011	Room D50	sink #1		6.7	Passed				
SHS-012	Room D50	sink #2		27.2	Failed			10/11/2018	ND
SHS-013	Room D50	sink #3		7.9	Passed				
SHS-014	Room D50	sink #4		12.1	Passed				
SHS-015	Room D50	sink #5		17.3	Failed			10/11/2018	ND
SHS-016	Room D50	sink #6		19.6	Failed			10/11/2018	ND
SHS-017	Room D50	sink #7		7.2	Passed				
SHS-018	Room D51	sink #1		36.8	Failed			10/11/2018	ND
SHS-019	Room D51	sink #2		18.1	Failed			10/11/2018	ND
SHS-020	Room D51	sink #3		6.9	Passed				
SHS-021	Room D51	sink #4		33.6	Failed			10/11/2018	ND
SHS-022	Room D51	sink #5		28.6	Failed			10/11/2018	ND
SHS-023	Room D51	sink #6		9.5	Passed				
SHS-024	Room D51	sink #7		40	Failed			10/11/2018	ND
SHS-025	Room D46	sink #1		77.2	Failed			10/11/2018	ND
SHS-026	Room D46	sink #2		200	Failed			10/11/2018	ND
SHS-027	Room D46	sink #3		246	Failed			10/11/2018	ND
SHS-028	Room D46	sink #4		118	Failed			10/11/2018	ND
SHS-029	Room D46	sink #5		70.6	Failed			10/11/2018	1.4
SHS-030	Room D46	sink #6		73.5	Failed			10/11/2018	1.9
SHS-031	Room D46	sink #7		42.2	Failed			10/11/2018	1.3
SHS-032	Room D52	sink #1		145	Failed			10/11/2018	ND

SHS-033	Room D52	sink #2		222	Failed			10/11/2018	ND
SHS-034	Room D52	sink #3		124	Failed			10/11/2018	ND
SHS-035	Room D52	sink #4		320	Failed			10/11/2018	1
SHS-036	Room D52	sink #5		125	Failed			10/11/2018	ND
SHS-037	Room D52	sink #6		366	Failed			10/11/2018	ND
SHS-038	Room D52	sink #7		8.9	Passed				
SHS-039	Room D47	sink #1		12.1	Passed				
SHS-040	Room D47	sink #2		8.3	Passed				
SHS-041	Room D47	sink #3		5.7	Passed				
SHS-042	Room D47	sink #4		8.9	Passed				
SHS-043	Room D47	sink #5		24.3	Failed			10/11/2018	ND
SHS-044	Room D47	sink #6		18.6	Failed			10/11/2018	ND
SHS-045	Room D47	sink #7		9.2	Passed				
SHS-046	Hallway across from Room D6B	water fountain		8.7	Passed				
SHS-047	Room D44	sink #1		24.6	Failed			10/11/2018	ND
SHS-048	Room D44	sink #2		75.6	Failed			10/11/2018	ND
SHS-049	Room D44	sink #3		3.3	Passed				
SHS-050	Room D44	sink #4		NO SAMPLE	Passed				ND
SHS-051	Room D44	sink #5		69.8	failed			10/11/2018	ND
SHS-052	Room D44	sink #6		18.7	failed			10/11/2018	ND
SHS-053	Room D44	sink #7		39.5	failed			10/11/2018	ND
SHS-054	Room D39	sink		6.6	Passed				
SHS-055	Room D28 in closet	sink		615	Failed			10/11/2018	Removed
SHS-056	Room D27	sink #1		18.7	Failed			10/11/2018	ND
SHS-057	Room D27	sink #2		19.4	Failed			10/11/2018	ND
SHS-058	Room D26	sink #1		29	Failed			10/11/2018	ND
SHS-059	Room D26	sink #2		45.6	Failed			10/11/2018	ND
SHS-060	Room D25	sink		26.5	Failed			10/11/2018	
SHS-061	Room D24	sink		32.4	Failed			10/11/2018	
SHS-062	Room D23	sink		24.8	Failed			10/11/2018	
SHS-063	Room D21	sink		NO SAMPLE	Passed				
SHS-064	Room D14	sink		12.8 OR 49.4	Failed			10/11/2018	Non-Potable
SHS-065	Room D15	sink		16.9 OR 245	Failed			10/11/2018	Non-Potable
SHS-066	Room D5	sink #1		NO SAMPLE	Passed				Lab
SHS-067	Room D5	sink #2		MISSING SAMPLE	Passed				Lab

SHS-068	Room D5	sink #3		NO SAMPLE	Passed				Lab
SHS-069	Room D5	sink #4		93.9	Failed			10/11/2018	Lab
SHS-070	Room D5	sink #5		242	Failed			10/11/2018	Lab
SHS-071	Room D5	sink #6		1.7	Passed				
SHS-072	Room D5	sink #7		141	Failed			10/11/2018	Lab
SHS-073	Room D4	sink #1		NO SAMPLE	Passed				Lab
SHS-074	Room D4	sink #2		269	Failed			10/11/2018	Lab
SHS-075	Room D4	sink #3		NO SAMPLE	Passed				Lab
SHS-076	Room D4	sink #4		6260	Failed			10/11/2018	Lab
SHS-077	Room D4	sink #5		NO SAMPLE	Passed				Lab
SHS-078	Room D4	sink #6		136	Failed			10/11/2018	Lab
SHS-079	Room D4	sink #7		6.8	Passed				Lab
SHS-080	Hallway Middle D-Wing next to Boys Bathroom	water fountain		13.7	Passed				
SHS-081	Hallway Main Hallway outside Commons	water fountain		11.2	Passed				
SHS-082	Room D1	sink #1		20.2	Failed			10/11/2018	3.2
SHS-083	Room D1	sink #2		29.4	Failed			10/11/2018	1.9
SHS-084	Room D1	sink #3		34.6	Failed			10/11/2018	1.2
SHS-085	Room D1	sink #4		40	Failed			10/11/2018	ND
SHS-086	Room D1	sink #5		33.9	Failed			10/11/2018	1.1
SHS-087	Room D1	sink #6		44.8	Failed			10/11/2018	1
SHS-088	Room D1	sink #7		33.9	Failed			10/11/2018	1
SHS-089	Room D2	sink #1		19.9	Failed			10/11/2018	ND
SHS-090	Room D2	sink #2		26.3	Failed			10/11/2018	ND
SHS-091	Room D2	sink #3		11.2	Passed				
SHS-092	Room D2	sink #4		27.6	Failed			10/11/2018	ND
SHS-093	Room D2	sink #5		22.2	Failed			10/11/2018	ND
SHS-094	Room D2	sink #6		11.5	Passed				
SHS-095	Room D2	sink #7		17	Failed			10/11/2018	ND
SHS-096	Cafeteria	water fountain		2.2	Passed				
SHS-097	Cafeteria Serving Line	sink #1		1.9	Passed				
SHS-098	Cafeteria Serving Line	sink #2		18.2	Failed			10/11/2018	NOT POTABLE
SHS-099	Kitchen prep	sink #1		1.9	Passed				
SHS-100	Kitchen prep	sink #2		12.6	Passed				
SHS-101	Kitchen prep	sink #3		1.2	Passed				
SHS-102	Kitchen	sink #1		2.3	Passed				

SHS-103	Kitchen	sink #2		6.8	Passed				
SHS-104	Kitchen	sink #3		3	Passed				
SHS-105	Hallway next to Room E6	water fountain		2.1	Passed				
SHS-106	Room E5	sink #1		6.6	Passed				
SHS-107	Room E5	sink #2		8	Passed				
SHS-108	Room E5	sink #3		9.7	Passed				
SHS-109	Room E5	sink #4		8.2	Passed				
SHS-110	Room E5	sink #5		8.9	Passed				
SHS-111	Room E5	sink #6		2.7	Passed				
SHS-112	Room E6	sink #1		8.9	Passed				
SHS-113	Room E6	sink #2		4.3	Passed				
SHS-114	Room E6	sink #3		6.4	Passed				
SHS-115	Room E6	sink #4		4.8	Passed				
SHS-116	Room E6	sink #5		10.5	Passed				
SHS-117	Room E6	sink #6		2.6	Passed				
SHS-118	Hallway E-Wing next to Boys Bathroom	water fountain		0.22	Passed				
SHS-119	Room E4	sink #1		13.6	Passed				
SHS-120	Room E4	sink #2		3.4	Passed				
SHS-121	Room E4	sink #3		8.6	Passed				
SHS-122	Room E4	sink #4		8.9	Passed				
SHS-123	Room E4	sink #5		13.6	Passed				
SHS-124	Room E4	sink #6		13.6	Passed				
SHS-125	Room E9	sink #1		11.5	Passed				
SHS-126	Room E9	sink #2		4.1	Passed				
SHS-127	Room E9	sink #3		5.9	Passed				
SHS-128	Room E9	sink #4		6.6	Passed				
SHS-129	Room E9	sink #5		6.3	Passed				
SHS-130	Room E9	sink #6		11.4	Passed				
SHS-131	Hallway E-Wing next to Girls Bathroom	water fountain		0.13	Passed				
SHS-132	Hallway E-Wing next to Room E7	water fountain		1.9	Passed				
SHS-133	Room E7	sink #1		17.2	Failed		10/11/2018		ND
SHS-134	Room E7	sink #2		16.5	Failed		10/11/2018		ND
SHS-135	Room E7	sink #3		9.3	Passed				
SHS-136	Room E7	sink #4		6.3	Passed				
SHS-137	Room E7	sink #5		7.1	Passed				

SHS-138	Room E7	sink #6		10	Passed				
SHS-139	Room E7	sink #7		3.4	Passed				
SHS-140	Room E8	sink #1		29.1	Failed			10/11/2018	2.1
SHS-141	Room E8	sink #2		33.9	Failed			10/11/2018	1.9
SHS-142	Room E8	sink #3		31.6	Failed			10/11/2018	ND
SHS-143	Room E8	sink #4		35.9	Failed			10/11/2018	ND
SHS-144	Room E8	sink #5		28.8	Failed			10/11/2018	ND
SHS-145	Room E8	sink #6		32.8	Failed			10/11/2018	ND
SHS-146	Room E8	sink #7		13	Passed				
SHS-147	Room A1	sink		10.1	Passed				
SHS-148	Hallway A-Wing across from Room A1	water fountain		5.6	Passed				
SHS-149	Room A9	sink		3.2	Passed				
SHS-150	Room A8	sink		5.9	Passed				
SHS-151	Room A11	sink		8.4	Passed				
SHS-152	Hallway A-Wing across from Room A14	water fountain		3.8	Passed				
SHS-153	Room A10	sink		1.2	Passed				
SHS-154	Hallway AB-Wing next to Room AB9	water fountain		1.6	Passed				
SHS-155	Hallway B-Wing across from Room B17	water fountain		13.2	Passed				
SHS-156	Hallway B-Wing across from Room B20	water fountain		5.2	Passed				
SHS-157	Room B23	sink		6.4	Passed				
SHS-158	Room B1	sink		4.6	Passed				
SHS-159	Room B12	sink		1.4	Passed				
SHS-160	Hallway B-Wing across from Room B7	water fountain		1.4	Passed				
SHS-161	Hallway next to Guidance Suite	water fountain		1.1	Passed				
SHS-162	Main Office next to Room D137	water fountain		10.5	Passed				
SHS-163	Nurses Office	sink #1		16.8	Failed			10/11/2018	1
SHS-164	Nurses Office	sink #2		5.2	Passed				
SHS-165	Nurses Office	sink #3		4	Passed				
SHS-166	Nurses Office	sink #4		20.5	Failed			10/11/2018	1.3
SHS-167	Nurses Office	sink #5		5.6	Passed				
SHS-168	Main Hallway across from Auditorium #1	water fountain		3.8	Passed				
SHS-169	Main Hallway across from Auditorium #2	water fountain		15.7	Failed			10/11/2018	NEW
SHS-170	Auditorium Stage	sink		9.9	Passed				
SHS-171	Hallway FA-Wing across from Room FA1 #1	water fountain		< 1.0	Passed				
SHS-172	Hallway FA-Wing across from Room FA1 #2	water fountain		< 1.0	Passed				

SHS-173	Hallway FA-Wing across from Room FA1 #1	water fountain		< 1.0	Passed				
SHS-174	2nd Floor Hallway FA-Wing next to Room FA25	water fountain		< 1.0	Passed				
SHS-175	2nd Floor Hallway FA-Wing next to Room FA25	water fountain		< 1.0	Passed				
SHS-176	2nd Floor FA-Wing Room 23	sink #1		52.6	Failed		10/11/2018		ND
SHS-177	2nd Floor FA-Wing Room 23	sink #2		58.7	Failed		10/11/2018		ND
SHS-178	2nd Floor FA-Wing Room 25	sink #1		0.94	Passed				
SHS-179	2nd Floor FA-Wing Room 25	sink #2		0.92	Passed				
SHS-180	2nd Floor FA-Wing Room 26	sink #1		0.76	Passed				
SHS-181	2nd Floor FA-Wing Room 26	sink #2		0.86	Passed				
SHS-182	2nd Floor FA-Wing Room 22	sink #1		NO SAMPLE	Passed				
SHS-183	2nd Floor FA-Wing Room 22	sink #2		NO SAMPLE	Passed				
SHS-184	2nd Floor FA-Wing Room 21	sink #1		40.1	Failed		10/11/2018		1.4
SHS-185	2nd Floor FA-Wing Room 21	sink #2		107	Failed		10/11/2018		1.4
SHS-186	2nd Floor FA-Wing Room 27	sink #1		0.53	Passed				
SHS-187	2nd Floor FA-Wing Room 27	sink #2		0.52	Passed				
SHS-188	2nd Floor FA-Wing Room 27	sink #3		27.2	Failed		10/11/2018		ND
SHS-189	2nd Floor Hallway FA-Wing across from Room F	water fountain		0.36	Passed				
SHS-190	2nd Floor Hallway FA-Wing across from Room F	water fountain		0.4	Passed				
SHS-191	2nd Floor FA-Wing Room 20	sink		51.9	Failed		10/11/2018		ND
SHS-192	Room FA10	sink		4.5	Passed				
SHS-193	Room D11	sink		NO SAMPLE	Passed				
SHS-194	Room D9	sink #1		MISSING SAMPLE	Passed				
SHS-195	Room D9	sink #2		225	Failed		10/11/2018		Lab
SHS-196	Room D9	sink #3		139	Failed		10/11/2018		Lab
SHS-197	Room D9	sink #4		84	Failed		10/11/2018		Lab
SHS-198	Room D9	sink #5		61.6	Failed		10/11/2018		Lab
SHS-199	Room D9	sink #6		24.6	Failed		10/11/2018		Lab
SHS-200	Room D9	sink #7		44	Failed		10/11/2018		Lab
SHS-201	Room D49B	sink		13.6	Passed				
SHS-202	Room D10	sink		NO SAMPLE	Passed				
SHS-203	Room D22	sink #1		47.9	Failed		10/11/2018		Removed
SHS-204	Room D22	sink #2		77.1	Failed		10/11/2018		Removed
SHS-205	Room D17	sink #1		NO SAMPLE	Passed				
SHS-206	Room D17	sink #2		NO SAMPLE	Passed				
SHS-207	Room D17	sink #3		7.5	Passed				

SHS-208	Room D16	sink #1		7.4	Passed				
SHS-209	Room D16	sink #2		2.2	Passed				
SHS-210	Room D16	sink #3		2.7	Passed				
SHS-211	Room D16	sink #4		1.7	Passed				
SHS-212	Room D16	sink #5		1	Passed				
SHS-213	Room D8	sink #1		11.3	Passed				
SHS-214	Room D8	sink #2		127	Failed			10/11/2018	Lab
SHS-215	Room D8	sink #3		125	Failed			10/11/2018	Lab
SHS-216	Room D8	sink #4		95.1	Failed			10/11/2018	Lab
SHS-217	Room D8	sink #5		114	Failed			10/11/2018	Lab
SHS-218	Room D8	sink #6		69.8	Failed			10/11/2018	Lab
SHS-219	Pool Complex Boys Locker Room	sink #1		0.31	Passed				
SHS-220	Pool Complex Boys Locker Room	sink #2		2.9	Passed				
SHS-221	Pool Complex Girls Locker Room	sink #1		1.9	Passed				
SHS-222	Pool Complex Girls Locker Room	sink #2		2.2	Passed				
SHS-223	Boys Locker Room	water fountain		13.9	Passed				
SHS-224	FA-1	Sink		ND	Passed				
SHS-225	FA-2	Sink		ND	Passed				
SHS226	FA-3	Sink		ND	Passed				
SHS-227	FA-4	Sink		ND	Passed				
SHS-228	FA-5	Sink		ND	Passed				
SHS-229	FA-6	Sink		ND	Passed				
SHS-230	FA-7	Sink		ND	Passed				
SHS-231					Passed				
SHS-232					Passed				
SHS-233	FA-10	Sink		ND	Passed				
SHS234	FA-11	Sink		ND	Passed				
SHS235	FA-12	Sink		ND	Passed				

